Rate Code: L L-17-DRB

- 1 -

SOUTH CAROLINA PUBLIC SERVICE AUTHORITY

(SANTEE COOPER)
LARGE LIGHT AND POWER

DEMAND RESPONSE BUY BACK (DRB) SCHEDULE L-17-DRB

Section 1. Limited Availability:

(A) Service hereunder, “Demand Response Buy Back,” is available to Customers meeting
the availability requirements of the Authority’s Large Light and Power Rate Schedule L-17 or its

Rate Code: L L-17-DRB

- 2 -

(A) Demand Response Buy Back shall be interruptible or curtailable service with a short

Rate Code: L L-17-DRB

- 4 -

(B) Notice

Notice for immediate customer action by the Authority of a Demand Response Buy Back
interruption or curtailment could be two (2) minutes or less and not more than ten (10) minutes.
(C) Duration

The duration of a single Demand Response Buy Back Curtailment Period will be one (1)
hour or less. Under typical circumstances, the Curtailment Period will not exceed one (1) hour.

(D) Major Disturbance

In the event of a major disturbance, as defined by the Authority, greater frequency, less
notice, or longer duration than listed above may occur. In the event of a major disturbance, the Customer

Rate Code: L L-17-DRB

- 5 -

Section 7. Special Provisions:

(A) Monitoring of the Customer’s load shall be accomplished through the Authority’s use of
monitoring circuits connected directly to the Customer’s switching equipment of the Customer’s load and may be controlled by use of other means acceptable to the Authority.

(B) The Customer shall grant the Authority reasonable access for installing, maintaining,
inspecting, testing and/or removing Customer-owned communications and monitoring load control
equipment.

(C) It shall be the responsibility of the Customer to determine that all of its electrical
equipment to be controlled is in good repair and working condition. The Authority will not be responsible
for the repair, maintenance, or replacement of the Customer’s electrical equipment.

(D) The Authority will not be required to install load monitoring equipment if the l not ned comda (- 5d7504

ED)
and